



NOTES:

1. CONCRETE MINIMUM STRENGTH 4,000 PSI AFTER 28 DAYS.
2. REINFORCEMENT STEEL CONFORMS TO ASTM A615 GRADE 60 #6 REBAR.
3. 25 TO 250 KVA
4. MEETS OR EXCEEDS EVERSOURCE SPECIFICATIONS.
5. MAXIMO #566780

WEIGHT

PSNH250TP	3,022 LBS
-----------	-----------



New England's Premier Precaster
800-696-7432 (SHEA)
www.sheaconcrete.com

**EVERSOURCE 53-102L
TRANSFORMER PAD
25 TO 250 KVA**

773 Salem Street-Wilmington, MA 01890 | 153 Cranberry Hwy-Rochester, MA 01867
87 Haverhill Road-Amesbury, MA 01825 | 160 Old Turnpike Rd-Nottingham, NH 03255
Mail to: PO Box 520-Wilmington, MA 01887

Page: _____
DWG: 53-102L TRANSFORMER PAD
Drafter: CAM
Revision: 3
Date: 01.26.24

