


PLAN



SECTION A-A

NOTES:

1. CONCRETE: 5,000 PSI MINIMUM AFTER 28 DAYS.
2. DESIGN LOADING: AASHTO HS20-44, 0 TO 5 FEET COVER.
3. DESIGN SPECIFICATIONS - ACI 318 & AASHTO LOAD FACTOR DESIGN METHOD.
4. STEEL REINFORCEMENT CONFORMS TO ASTM A615, GRADE 60. MINIMUM STEEL COVER 1 1/2".

SHEA PRODUCT ID: NSTP3801-2

FILE NAME: ES-MA TP 3801-2

WEIGHT (LBS): 9280

DRAWN BY: L.P.

DATE: 12/18/2017

PAGE: I I.C.2

