


PLAN



ELEVATION A

NOTES:

1. CONCRETE MINIMUM STRENGTH 5,000 PSI AFTER 28 DAYS.
2. STEEL REINFORCEMENT – ASTM A615, GRADE 60., 1" MIN. COVER.
3. DESIGNED FOR HS20-44 LOADING.



New England's Premier Precaster

800-696-7432 (SHEA)

www.sheaconcrete.com

NSTAR TRANSFORMER PAD
RETAINING WALL

773 Salem Street—Wilmington, MA 153 Cranberry Hwy—Rochester, MA
 87 Haverhill Road—Amesbury, MA 160 Old Turnpike Rd—Nottingham, NH
 Mail to: PO Box 520—Wilmington, MA 01887

Page: K6.24

NSTAR Retaining Wall.dwg 01/01/2013

