


PLAN



SECTION A-A

NOTES:

1. CONCRETE: 5,000 PSI MINIMUM AFTER 28 DAYS.
2. DESIGN LOADING: AASHTO HS20-44, 0 TO 5 FEET COVER.
3. DESIGN SPECIFICATIONS - ACI 318 & AASHTO LOAD FACTOR DESIGN METHOD.
4. STEEL REINFORCEMENT CONFORMS TO ASTM A615, GRADE 60. MINIMUM COVER 1"

SHEA PRODUCT ID: PL750KVATP	FILE NAME: PL 750-1500KVA		
WEIGHT (LBS): 5925	DRAWN BY: L.P.	DATE: 5/9/2018	PAGE: VIII.G.2

