



**TOTAL SYSTEM CAPACITY: 1,300 GALLONS**  
**RATED CAPACITY: 500-600 GALLONS PER DAY**

**NOTES:**

1. CONCRETE: 4,000 PSI MINIMUM AFTER 28 DAYS.
2. DESIGN CONFORMS WITH 310 CMR 15.00, DEP TITLE 5 REGS, FOR ALTERNATE SEPTIC SYSTEMS
3. ALL REINFORCEMENT PER ASTM C1227-93.
4. TONGUE & GROOVE JOINT SEALED WITH BUTYL RESIN.



*New England's Premier Precaster*  
 800-696-7432 (SHEA)  
 www.sheaconcrete.com

**SINGULAIR® BIO-KINETIC® MODEL 960**  
**WASTEWATER TREATMENT SYSTEM**

773 Salem Street  
 P.O. Box 520  
 Wilmington, MA 01887

87 Haverhill Road  
 P.O. Box 807  
 Amesbury, MA 01913

160 Old Turnpike Road  
 Nottingham, NH 03290

Page: B3

Singulair.dwg

11/30/2009

