




PLAN (3'x6')




PLAN (3'x8')



SECTION A-A



SECTION B-B



SECTION C-C

NOTES:

1. CONCRETE MINIMUM STRENGTH 4,000 PSI AFTER 28 DAYS.



New England's Premier Precaster
 800-696-7432 (SHEA)
 www.sheaconcrete.com

UNITIL SERVICE CORP.
 SECTIONALIZER PAD (1PH/3PH)

773 Salem Street—Wilmington, MA 153 Cranberry Hwy—Rochester, MA
 87 Haverhill Road—Amesbury, MA 160 Old Turnpike Rd—Nottingham, NH
 Mail to: PO Box 520—Wilmington, MA 01887

Page: K4.2

UNITIL-SP.dwg

01/01/2013

