



NOTES:

1. CONCRETE: 5,000 PSI MINIMUM AFTER 28 DAYS.
2. DESIGN CONFORMS WITH 310 CMR 15.00, DEP TITLE 5 REGS, FOR SEPTIC TANKS
3. ALL REINFORCEMENT PER ASTM C1227.
4. DESIGNED FOR AASHTO HS-20 LOADING, 1 TO 5 FT COVER.
5. TONGUE & GROOVE JOINT SEALED WITH BUTYL RESIN
6. TEES AND BAFFLES SOLD SEPARATELY
7. BAFFLE WALL OPTIONAL FOR TWO COMPARTMENT TANKS.

ITEM NO.	CTK-M2500C	WEIGHT
	CTK-M2500C2C	35,358#

WEIGHT	ONE COMPART	TWO COMPART
TOP SECTION	9,475#	9,475#
BOTTOM SECTION	23,345#	25,883#

SHEA PRODUCT ID:  
SEE TABLE

PREPARED FOR:

FILE NAME:  
ctkM2500.dwg

WEIGHT (LBS):  
SEE TABLE

DRAWN BY:  
ARO

DATE:  
06/01/18

PAGE:  
I 4

