


2" TAPER

NOTES:

1. CONCRETE: 4,000 PSI MINIMUM AFTER 28 DAYS.
 2. CONSTRUCTION OF SEPTIC TANK CONFORMS WITH 310 CMR, SECTION 15.00 DEP TITLE 5 REGS.
 3. ALL REINFORCEMENT PER ASTM C1227.
 4. BAFFLE WALL OPTIONAL FOR TWO COMPARTMENT TANKS.
 5. TEES AND GAS BAFFLE SOLD SEPARATELY.
 6. TONGUE & GROOVE JOINT SEALED WITH BUTYL RESIN.
 7. IF COVER EXCEEDS 4 FEET, HEAVY DUTY TANK REQUIRED.
- ALSO AVAILABLE IN AASHTO HS-20 LOADING.

SHEA PRODUCT ID: M1500/M15002C	PREPARED FOR:	FILE NAME: tkm1500-3.dwg	
WEIGHT (LBS): 11,035#/11,841#	DRAWN BY: ARO	DATE: 06/01/18	
773 Salem Street-Wilmington, MA 153 Cranberry Hwy-Rochester, MA 87 Haverhill Road-Amesbury, MA 160 Old Turnpike Rd-Nottingham, NH			