



NOTE: PRETREATMENT CHAMBER MINIMUM REQUIREMENTS SHALL BE: 1,000 GALLONS CAPACITY, 15 GALLONS PER INCH OF LIQUID LEVEL AND 12 INCHES OF FREEBOARD.

SECTION A-A

NOTE: SOME CRITICAL DIMENSIONS ARE INTENTIONALLY LEFT BLANK TO BE FILLED IN PER INDIVIDUAL JOB-SITE SPECIFICATIONS.

NOTE: TOTAL SYSTEM CAPACITY: 2,300 GALLONS  
RATED CAPACITY: 1,000 GALLONS PER DAY

NOTES:

1. CONCRETE: 4,000 PSI MINIMUM AFTER 28 DAYS.
2. DESIGN CONFORMS WITH 310 CMR 15.00, DEP TITLE 5 REGS, FOR ALTERNATE SEPTIC SYSTEMS
3. ALL REINFORCEMENT PER ASTM C1227-93.
4. TONGUE & GROOVE JOINT SEALED WITH BUTYL RESIN.

TOTAL SYSTEM CAPACITY: 2,300 GALLONS  
RATED CAPACITY: 1000 GALLONS PER DAY

SHEA PRODUCT ID: S1000XX

PREPARED FOR:

FILE NAME: Singulair1000GPD.dwg

WEIGHT (LBS): 10,500#

DRAWN BY: ARO

DATE: 03/01/2018

PAGE: B3.2

