



NOTES:

1. CONCRETE: 4,000 PSI MINIMUM AFTER 28 DAYS.
2. CONSTRUCTION OF SEPTIC TANK CONFORMS WITH 310 CMR, SECTION 15.00 DEP TITLE 5 REGS.
3. ALL REINFORCEMENT PER ASTM C1227.
4. BAFFLE WALL OPTIONAL FOR TWO COMPARTMENT TANKS.
5. TEES AND GAS BAFFLE SOLD SEPARATELY.
6. TONGUE & GROOVE JOINT SEALED WITH BUTYL RESIN.
7. IF COVER EXCEEDS 4 FEET, HEAVY DUTY TANK REQUIRED. ALSO AVAILABLE IN AASHTO HS-20 LOADING.

		WEIGHT
ITEM NO. 1500	STANDARD	11,670#
1500H	H-20	13,135#
15002C	STANDARD	12,930#
15002CH	H-20	14,395#

SHEA PRODUCT ID:
SEE TABLE

PREPARED FOR:

FILE NAME: tk1500.dwg

WEIGHT (LBS):
SEE TABLE

DRAWN BY: ARO

DATE: 06/01/18

PAGE: B1.3

